

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.

rwtlasr1@gmail.com

To,

Principal Little Flowers Model Sen.Sec. School
Opp.Central Bank of India.Gehri Mandi,Amritsar


No.: RWTLASR/2526/00372 Dated : 26/06/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 470 Dated: 24/06/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 25/06/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar



TC-13602

TEST REPORT

Name & Address of Customer : Principal Little Flowers Model Sen.Sec. School Opp.Central Bank of India.Gehri Mandi,Amritsar		Customer Reference No.	No : 470 Dated : 24/06/2025	
		Sample Submitted by	S. Sardul Singh	
		Date of Sample Receipt	25/06/2025	
		Analysis Starting Date	25/06/2025	
		Analysis completion Date	26/06/2025	
Discipline : Chemical Testing		Group: Water		
ULR No.:	TC136022500000524F	Sample Type :	Water	
Test Report No.:	RWTLASR/2526/00372	Date of Issue :	26/06/2025	
Registration no.:	RWTLASR/REG2526/02914	Condition of Sample :	Sealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Gehri Mandi(RO) / NA	
Village :	Not Mentioned	Habitation :	Not Mentioned	
Block:	Not Mentioned	District :	Amritsar	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.60@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	215	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	172	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	160	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	32.06	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	19.44	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	21.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±2b%

Reviewed and Approved By

Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar